



**QUALITY CERTIFICATE**  
**EN 10204 / 3.1**

REPORT NO

DATE

7.04.2023

CLIENT

*P.V.F. TRADERS D.O.O.-*  
*DYV2023000000154*

**NAME OF PRODUCT**

TYPE OF VALVE

*GLOBE VALVE*

NOMINAL DIAMETER ( DN ) mm

*DN 100*

NOMINAL PRESSURE (PN) bar

*PN 16*

STANDARD / DESIGN

*TS EN 13789*

END CONNECTION

*TS EN 1092-2*

QUANTITY

*10*

Nominal Diameter

QUANTITY

Nominal Diameter

QUANTITY

*DN 100*

*10 PCS*

**SPECIFICATION OF MATERIALS**

Body

*EN JL 1040 (GG 25)*

Packing

*GRAFİT (GRAPHITE)*

Flange

*EN JL 1040 (GG 25)*

Packing Gland

*CuZn40Pb2 (BRASS)*

Handwheel

*EN JL 1040 (GG 25)*

Gasket

*KLINGERIT*

Stem

*AISI 420 (STAINLESS*  
*STEEL)*

Disc

*AISI 420 (STAINLESS STEEL)*

Seat

*AISI 304 (STAINLESS STEEL)*

**TEST CONDITIONS**

TEST LIQUID

*WATER*

BODY TEST

*24 BAR*

LEAKAGE TEST

*18 BAR*

TEST STANDART NO

*TS EN 12266-1*

**TYPICAL CHEMICAL ANALYSIS**

C

Mn

Si

P

S

*3,12*

*0,56*

*2,1*

*0,041*

*0,043*

INSIDE CLEANING

PAINTING&COLOR

END COVER

MARKING

*OK*

*BLUE*

*OK*

INSPECTOR / *Zafer KUYVET*

QUALITY ASSURANCE DIRECTOR / *Veysel ATILGAN*

**DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.**

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAC / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyar.com e-mail: info@duyar.com



**DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.**

Osmangazi Mah. 2653 Sok. No:7 Esenyurt/İSTANBUL

Pbx: 444 82 62 Faks: 0 212 355 07 47

Marmara Kurumlar V.D. : 320 003 9012

DUYAR 20-047