



<b>QUALITY CERTIFICATE</b> <b>EN 10204 / 3.1</b>		REPORT NO			
		DATE	7.04.2023		
		CLIENT	P.V.F.TRADERS D.O.O.- DYV2023000000154		
<b>NAME OF PRODUCT</b>					
TYPE OF VALVE		SPRINKLER UPRIGHT			
NOMINAL DIAMETER ( DN ) mm		DN			
NOMINAL PRESSURE (PN) bar		PN12			
STANDARD / DESIGN		TS EN 12259-1			
END CONNECTION		ISO 7 / 1 (Male Thread)			
QUANTITY		300			
Nominal Diameter		QUANTITY	Nominal Diameter	QUANTITY	
DN		300 PCS			
<b>SPECIFICATION OF MATERIALS</b>					
Body	CuZn40Pb2 (Ms58)				
Bulb slot	CuZn40Pb2 (Ms58)				
Bulb	Glass+Liquid				
Packing	Be-Ni Alloy + Teflon coated				
Deflector	Paslanmaz Çelik (CF 8)				
Grub	Stainless Steel (CF 8)				
<b>TEST CONDITIONS</b>					
TEST LIQUID	WATER				
BODY TEST	34,5 BAR				
LEAKAGE TEST	34,5 BAR				
TEST STANDART NO	TS EN 12845 + A2				
<b>TYPICAL CHEMICAL ANALYSIS</b>					
Mn	P	Cu	Pb	Sn	Zn
0,04	0,01	57,42	2,71	0,038	39,42
INSIDE CLEANING	OK				
PAINTING&COLOR					
END COVER					
MARKING	OK				
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE DIRECTOR / VeySEL ATILGAN			

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZİ MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyar.com e-mail: info@duyar.com

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.  
Osmanğazi Mah. 2653 Sok. No:7 Esenyurt/İSTANBUL  
Pbx: 444 82 62 Faks: 0 212 355 07 47  
Marmara Kurumlar V.D. : 320 003 9012

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş. 20-047