



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO			
	DATE	7.04.2023		
	CLIENT	P.V.F.TRADERS D.O.O.- DYV2023000000154		
NAME OF PRODUCT				
TYPE OF VALVE	OS&Y METAL SEATED GATE VALVE			
NOMINAL DIAMETER (DN) mm	DN 100			
NOMINAL PRESSURE (PN) bar	PN 16			
STANDARD / DESIGN	TS EN 1171			
END CONNECTION	BS EN 1092-2			
QUANTITY	5			
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 100	5 PCS			
SPECIFICATION OF MATERIALS				
Body	EN JS 1030 (GGG 40)	Handwheel	EN JL 1040 (GG 25)	
Bonnet	EN JS 1030 (GGG 40)			
Wedge	EN JS 1030 (GGG 40)			
Stem	AISI 420			
Seat	CuZn40Pb2			
Gasket	EPDM			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	24 BAR			
LEAKAGE TEST	12 BAR			
TEST STANDART NO	TS EN 12266-1			
TYPICAL CHEMICAL ANALYSIS				
<u>C</u>	<u>Mn</u>	<u>Si</u>	<u>P</u>	<u>S</u>
3,75	0,13	2,47	0,005	0,012
INSIDE CLEANING				
PAINING&COLOR	OK			
END COVER	BLACK			
MARKING	OK			
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE DIRECTOR / Veysel ATILGAN		

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH.2653 SOK. NO :7 /1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyar.com e-mail: info@duyar.com

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZI MAH. 2653 SOK. NO:7 ESENYURT/İSTANBUL

Pbx: 444 82 62 Faks: 0 212 355 07 47

Marmara Kurumlar V.D. : 320 003 9012

DUYAR 20-047