



QUALITY CERTIFICATE EN 10204 / 3.1		REPORT NO		
		DATE	7.04.2023	
		CLIENT	P.V.F. TRADERS D.O.O.- DYV2023000000154	
NAME OF PRODUCT				
TYPE OF VALVE		DRY ALARM VALVE		
NOMINAL DIAMETER (DN) mm		DN 100		
NOMINAL PRESSURE (PN) bar		300 PSI		
STANDARD / DESIGN		UL 260, FM 1021		
END CONNECTION		TS EN 12259-3		
QUANTITY		9		
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY	
DN 100	9 PCS			
SPECIFICATION OF MATERIALS				
Body	EN GJS 400	Plug	X20Cr13	
Clapper	EN GJS 400	Label	Aluminium	
Body Sit	RG5 Bronz			
Bonnet	EN GJS 400			
Gasket	EPDM			
Clapper Stem	X20Cr13			
TEST CONDITIONS				
TEST LIQUID	WATER			
BODY TEST	42 BAR			
LEAKAGE TEST	21 BAR			
TEST STANDART NO	TS EN 12259-3 / UL260 / FM 1021			
TYPICAL CHEMICAL ANALYSIS				
<u>C</u>	<u>Mn</u>	<u>Si</u>	<u>P</u>	<u>S</u>
3.62	0.08	2.5	0.038	0.018
INSIDE CLEANING				
PAINTING&COLOR	OK			
END COVER	OK			
MARKING	RED			
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE DIRECTOR / Vessel ATILGAN		