



QUALITY CERTIFICATE EN 10204 / 3.1	REPORT NO				
	DATE	7.04.2023			
	CLIENT	P.V.F. TRADERS D.O.O.- DYV2023000000154			
NAME OF PRODUCT					
TYPE OF VALVE	SPRINKLER PENDENT				
NOMINAL DIAMETER (DN) mm	DN				
NOMINAL PRESSURE (PN) bar	PN 12				
STANDARD / DESIGN	TS EN 12259-1				
END CONNECTION	ISO 7 / 1				
QUANTITY	200				
Nominal Diameter	QUANTITY	Nominal Diameter	QUANTITY		
DN	200 PCS				
SPECIFICATION OF MATERIALS					
Body	CuZn40Pb2 (Ms 58)				
Bulb slot	CuZn40Pb2 (Ms 58)				
Bulb	Glass+Liquid				
Packing	Be - Ni Alloy + Teflon Coated				
Deflector	Stainless Steel (CF 8)				
Grub	Stainless Steel (CF 8)				
TEST CONDITIONS					
TEST LIQUID	WATER				
BODY TEST	34,5 BAR				
LEAKAGE TEST	34,5 BAR				
TEST STANDART NO	TS EN 12845 + A2				
TYPICAL CHEMICAL ANALYSIS					
Mn	P	Cu	Pb	Sn	Zn
0,04	0,01	57,42	2,71	0,038	39,42
INSIDE CLEANING					
PAINTING&COLOR	OK				
END COVER					
MARKING	OK				
INSPECTOR / Zafer KUVVET		QUALITY ASSURANCE DIRECTOR / Veysel ATILGAN			

DUYAR VANA MAKİNA SAN. VE TİC. A.Ş.

OSMANGAZİ MAH.2653 SOK. NO : 7 / 1 KIRAÇ / ESENYURT / İSTANBUL - TÜRKİYE

TEL: + 90 212 444 82 62 - FAX: + 212 355 07 47

website: www.duyar.com e-mail: info@duyar.com

DUYAR

DUYAR VANA MAKİNA SAN. ve TİC. A.Ş.

Osmangazi Mah. 2653 Sok. No:7 Esenyurt/İSTANBUL

Pbx: 444 82 62 Faks: 0 212 355 07 47

Marmara Kurumlar V.D. : 320 003 9012